

CHAFFEE COUNTY BUILDING DEPARTMENT

P.O. BOX 699
SALIDA, COLORADO 81201

PHONE: (719) 539-2124

FAX: (719) 530-9208

Owner _____ Date 11-2-21 Contractor _____

Location 10795 C.R 197-A

Type of Inspection Water Line AS Below Approved Disapproved

Information or Corrections:

Leak Section Replaced - 40 yds @
IN Washington Street -

248, 249, 250, 251 - Spares

1" PVC ASTM D1785 -

OK to Cure after
Proper Bedding

**AFTER CORRECTIONS ARE COMPLETE
PLEASE CALL FOR A REINSPECTION**

Time of Arrival _____ Time of Departure _____

Inspector [Signature]